



NATIONAL INSTITUTE OF TECHNICAL TEACHERS' TRAINING & RESEARCH
SECTOR-26, CHANDIGARH-160019 (INDIA)

(Established by Ministry of Human Resource Development, Govt. of India)

EPABX: 2759500, 2759514

FAX: 0172-2791366, 2793893

e-mail : director@nitttrchd.ac.in,

web site: www.nitttrchd.ac.in

NITTTR/CCT&SD/R-1

Dated: 30-06-2021

To

Headmistress
Govt Model High. School,
Khuda Jassu, Chandigarh.


Subject:- Condition assessment and stability certificate


Reference : Your letter no GMHS/Khuda Jassu/56/ on dated 29/06/2021.

Dear Sir,

As per the site inspection and test results of Non destructive testing results of Govt. Model High School, Khudda Jassu, Chandigarh. Following conclusions are drawn:

- The average relative strength of concrete varies from 22-25.5N/mm² corresponding to the rebound hammer test.
- The general quality of concrete is in the range of good corresponding to the Ultra sonic Pulse Velocity test.
- The load carrying capacity of the slab and beams can be calculated based on concrete grade M20 and design is found ok as per the relevant codal provisions.
- The load carrying capacity of the column can be calculated based on concrete grade=M20
- Since the quality of concrete is very good, it shows the absence of corrosion, honeycombing, cracks and voids etc at the locations where test were conducted.
- As per test results mentioned above the construction is carried out as per the approved design and drawings.
- The drawings and design of the buildings are also checked in accordance with the relevant Indian Standard Codes (with latest amendments) including Indian Standard Codes for structure resistant to earthquake.
- The existing structure design is stable as per IS Code requirement.


Dr. Sanjay Sharma
Prof & Head
Civil engineering Department
NITTTR, Sector 26, Chandigarh


Headmaster
Govt. Model High School
Khuda Jassu U.T CHD